



Product Specifications

Pro Series 200 Electric Valve / Professional Valve Series

Model # 7201, 7201-BSP, 7201-J, 7202, 7202-BSP, 7215, 7215-BPS

The electric valve shall be a normally closed, electronically-actuated, diaphragm-operated, remote-control zone valve. The valve will be capable of operating between _____ and _____ PSI (bars; kPa) with a flow range of between _____ and _____ GPM (m³/hr; l/m). Pressure loss shall be _____ PSI (bars; kPa) at a maximum of _____ GPM (m³/hr; l/m). The standard solenoid shall be a 24 VAC, 60 cycle unit with a .43 Amps inrush current and .25 Amps holding current. The valve shall open or close in less than 1 minute at 200 PSI (13,8 bar), and less than 30 seconds at 6 PSI (.4 bar).

The valve design shall have a large-opening, heavy-duty, rubber diaphragm/piston assembly allowing for straight flow path of the water to increase the flow rate while reducing the friction loss. The diaphragm shall have a metering screen of 50 mesh filter in the turbulent flow of water allowing for self-cleaning action during operation. The valve shall be debris tolerant in design for potable or non-potable water applications. All metal parts internal to the valve shall be manufactured from corrosion-resistant stainless steel.

The body and bonnet shall be molded of non-corrodible, glass-filled nylon construction rated to 200 PSI (13,8 bars/1379 kPa). The bonnet screws shall be stainless steel and serviceable with a Phillips screwdriver. The solenoid shall be an encapsulated, one-piece unit with captive plunger to allow for easy removal when servicing. The solenoid shall be equipped with a manual internal open/close capability to release the upper chamber water to the downstream piping, allowing the valve to open without electrically energizing the unit. The valve shall operate electrically, or manually by means of adjusting the external bleed screw.

The valve shall have a non-rising stem-type, flow control mechanism with removable tamper-resistant handle allowing for precise flow adjustment and manual shut off. The valve shall be equipped with a water flow indicator to ensure proper installation. When specified, the valve shall be equipped with a threaded jar-top to allow for quick, manual removal of the cap for servicing and installation (7201-J). The valve shall have an overall length of _____ inches (cm), a width of _____ inches (cm), and a height of _____ inches (cm). The valve with the optional flow control handle installed shall have an overall length of _____ inches (cm), a width of _____ inches (cm), and a maximum height of _____ inches (cm). When specified, the inlet diameter shall measure 1-inch (2.5 cm), 1 ½-inch (3.8 cm) or 2-inch (5.1 cm) female thread. The valve shall be adjustable by a flat blade screwdriver for operation without the handle.



Product Specifications

The valve is manufactured for four (4) different applications:

1. To accept 1-inch (2.5 cm) female thread;
2. To accept 1-inch (2.5 cm) female thread, jar-top;
3. To accept 1 ½-inch (3.8 cm) female thread; and
4. To accept 2-inch (5.1 cm) female thread.

The valve shall carry a five-year trade, exchange warranty.

The valve shall be manufactured by K-Rain Manufacturing Corporation of Riviera Beach.